

# **Bodycote Report**

---

## **EVALUATION ACCORDING TO ASTM F 2023**

**Evaluation of the chlorine resistance according to ASTM F 2023 of the  
PB pipe material PB4267 GREY**

Mattias Svedberg

SE-611 82 Nyköping, Sweden

Phone +46 155 22 14 76

Fax +46 155 26 31 25

E-mail info@bodycotepolymer.com

2007-01-31

P-8129

Handled by:  
Mattias SvedbergBasell Polyolefine GmbH  
Industriepark Höchst, D 536  
65926 Frankfurt (M)  
Germany

Tech contact: Dr. Klaus Könnecke

**EVALUATION ACCORDING TO ASTM F 2023****Evaluation of the chlorine resistance according to ASTM F 2023 of the  
PB pipe material PB4267 GREY****Abstract**

Basell Polyolefine GmbH has initiated a test program in order to evaluate the chlorine resistance of PB pipe material PB4267 GREY according to ASTM F 2023.

12 pipe specimens have been started at 95, 105 and 115°C. The chlorine level was set to 4 ppm and the pH level to 6.8.

Calculations of the estimated time-to-failure according to ASTM F 2023 have been performed. The table below shows the estimated times to failure for the condition called Traditional Domestic (CI-TD) and Domestic Continuous Re-circulation (CI-R).

<b>Condition</b>	<b>Temperature</b>	<b>Hoop stress</b>	<b>Service time fraction</b>	<b>Estimated time to failure</b>
Traditional domestic (CI-TD)	23°C (73°F)	2.20 MPa	75%	253 years
	60°C (140°F)	2.20 MPa	25%	
Domestic Continuous Re-circulation (CI-R)	60°C (140°F)	2.20 MPa	100%	65 years

All estimations in this report are only valid for the investigated PB pipe material PB4267 GREY with the Bodycote code 3527.

**LIST OF CONTENTS**

<b>1</b>	<b>Aim of the project</b>	<b>3</b>
1.1	Summary of the ASTM F2023 test method	3
1.2	Bodycote Polymer approach	3
1.3	Failure types	3
<b>2</b>	<b>Investigated pipe material</b>	<b>4</b>
<b>3</b>	<b>Experimental procedure</b>	<b>5</b>
3.1	Chlorine circulation loop	5
<b>4</b>	<b>Extrapolation techniques</b>	<b>6</b>
4.1	Multiple linear regression	6
4.2	Miner's rule	6
<b>5</b>	<b>Results from the chlorine circulation loop testing</b>	<b>7</b>
5.1	Testing at 95°C	7
5.2	Testing at 105°C	7
5.3	Testing at 115°C	7
<b>6</b>	<b>Evaluation according to ASTM F2023</b>	<b>8</b>
6.1	Extrapolation hoop stress	8
6.2	Multiple linear regression analysis	9
6.3	Lifetime calculations	9
<b>7</b>	<b>Additional comments</b>	<b>9</b>
<b>8</b>	<b>Referred documents</b>	<b>10</b>

**Appendices**

A	Client info
B	Investigated pipe material and pressure testing tables
C	Stress rupture diagram
D	Multiple linear regression diagram

Report written by

Mattias Svedberg  
*Operations Manager*

Reviewed by

Approved by

Joakim Jansson  
*Project Manager*

Jarno Hassinen  
*Technical Manager*

## 1 Aim of the project

The aim of this project was to evaluate the effect of chlorinated water on the lifetime of PB pipe material PB4267 GREY delivered by Basell. The method of approach has been ASTM F 2023.

### 1.1 Summary of the ASTM F 2023 test method<sup>1</sup>

*The PEX tubing or tubing/fitting assemblies are exposed to pressurized test-fluid until failure. All time-to-fail data used for analysis shall be the result of oxidative degradation (Stage III). A minimum number of test temperature and hoop stress conditions are required to allow accurate data analysis and time-to-failure extrapolations.*

*NOTE 2—The procedures described in this test method (with some modifications of test temperatures or stresses, or both) have been used to evaluate pipes manufactured from polybutylene (PB), polyethylene (PE), polypropylene (PP), multilayer (polymer-metal composite), copper, and stainless steel.*

### 1.2 Bodycote Polymer approach

Bodycote Polymer applies the ASTM F 2023 as follows; the tubing is tested at three temperatures (95, 105 and 115°C) and at two different pressure levels at each temperature with the aim to only generate Stage III failures. If a failure occurs that cannot be classified as Stage III, pipes will be started at a lower pressure level in order to allow accurate data analysis.

When an accurate data set has been achieved, it is analyzed using ISO 9080, 3- and 4-parameter models. The model with the best fit is then used for the time-to-failure extrapolations applying the given service conditions in ASTM F 2023.

### 1.3 Failure types

ASTM F 2023 requires that all data used for analysis shall be the result of environmental or oxidative degradation (Stage III). This report refers to Stage III failures as brittle failures.

---

<sup>1</sup> Recitation from ASTM F 2023

2007-01-31

## 2 Investigated pipe material

Basell delivered the 16 mm SDR<sup>2</sup> 9 PB pipe material, PB4267 GREY. All pipes show good visual appearance. The results obtained regarding the dimensions are shown in Table 1. All pipes showed small variations in the specific dimensions. Further information about the material is presented in Appendix B.

**Table 1** Dimension measurements results

<b>Code</b>	<b>Outer diameter</b>		<b>Min wall thickness</b>		<b>Max wall thickness</b>	
	<b>Mean<sup>3</sup></b> <i>mm</i>	<b>s<sup>4</sup></b> <i>mm</i>	<b>Mean</b> <i>mm</i>	<b>s</b> <i>mm</i>	<b>Mean</b> <i>mm</i>	<b>s</b> <i>mm</i>
3527	16.12	0.01	1.84	0.01	2.02	0.01

<sup>2</sup> Standard Dimension Ratio

<sup>3</sup> Mean value

<sup>4</sup> Standard deviation value

2007-01-31

### 3      Experimental procedure

All tests have been performed at Bodycote Polymer, Sweden, and in accordance with ASTM F 2023.

#### 3.1    Chlorine circulation loop

The components in the circulation loop are made of inert materials such as titanium, PVDF and PTFE. In the chlorine dosage unit, PE, PVC and PP components have been used. The fittings are made from PFA. The chlorine is produced using sodium hypochlorite at a known pH.

The test fluid is continuously purified after sample exposure through a state of the art filtering system including Reverse Osmosis (RO) to avoid contamination of the test fluid.

The pipes have been tested in series (vertically), i.e. the pipe ends are unrestrained and allowed to freely expand bi-directionally.

**Table 2**    Accuracy of temperature and pressure

Property	Value
Temperature accuracy, inside	±1°C
Temperature accuracy, outside	±2.5°C
Pressure accuracy	±0.2 bar

**Table 3**    Measured test parameters

Property	Set value	Average	s <sup>5</sup>
pH	6.8	6.83	0.08
Chlorine level (inlet)	4.0 ppm	3.97 ppm	0.08 ppm
ORP <sup>6</sup>	≥825 mV	878 mV	15 mV
Volume flow	54 dm <sup>3</sup> /h <sup>7</sup>	-	-

<sup>5</sup>Standard deviation

<sup>6</sup>Oxidation reduction potential

<sup>7</sup>Corresponds to 0.13 m/s for a 1/2" SDR 9 pipe

## 4      Extrapolation techniques

To predict the lifetime under constant conditions is multiple linear regression according to ISO 9080 used (conditions I-III)<sup>8</sup>. When the pipes are exposed to different operational conditions the multiple regression analysis is combined with Miner's rule (condition IV).

### 4.1      Multiple linear regression

The multiple linear regression method used for the determination of the time to failure ( $t_{fi}$ ) is based on ISO 9080. The 4-parameter model contains four regression coefficients  $C_1-C_4$  and two independent variables, temperature ( $T_i$ ) and stress ( $\sigma_i$ ). For the 3-parameter model is  $C_3=0$ .

**Equation 1**      *The 4-parameter model according to ISO 9080*

$$\text{Log}(t_{fi}) = C_1 + C_2 \cdot \frac{1}{T_i} + C_3 \cdot \text{Log}(\sigma_i) + C_4 \cdot \frac{\text{Log}(\sigma_i)}{T_i}$$

Equation 1 can be used for calculations of the expected failure time at any fixed combination of temperature and pressure (hoop stress) under constant service conditions.

### 4.2      Miner's rule

Assuming that each damage (caused by a constant service condition) is proportional to the duration of attack ("proportionality rule") and the damages from different service conditions "i" may be cumulatively added ("additivity rule") Miner's rule appears in ISO 13760 as:

**Equation 2**      *Miner's rule according to ISO 13760*

$$\frac{1}{t_f} = \sum_{i=1}^{i=n} \left[ \frac{t_i/t_{tot}}{t_{fi}(T_i, \sigma_i)} \right]$$

Where:

$t_f$	Lifetime at various conditions
$t_{fi}(T_i, \sigma_i)$	Failure time for condition "i"
n	Number of service conditions
$t_i$	Exposure time at condition "i"
$t_{tot}$	Total exposure time

The combination of equations 1 and 2 provides the tool for the determination of the expected lifetime of plastic materials subjected to varying service conditions, i.e. alterations in temperature and pressure.

---

<sup>8</sup> Refer to paragraph 6

2007-01-31

## **5      Results from the chlorine circulation loop testing**

12 pipe specimens were started of the PB pipe material PB4267 GREY (code 3527) at 95, 105 and 115°C. The internal medium was chlorinated water of 4 ppm and the external medium was air. The results are presented in Appendix B and shown in Appendix C.

All pipes started have whitened inner surfaces and failed in a brittle manner.

### **5.1    Testing at 95°C**

At 95°C two pipes were started at each pressure level of 6.0 and 4.5 bar. The average failure times are 13 350 h and 15 922 h, respectively.

### **5.2    Testing at 105°C**

At 105°C two pipes were started at each pressure level of 4.5 and 3.0 bar. The average failure times are 5 292 h and 8 183 h, respectively.

### **5.3    Testing at 115°C**

At 115°C two pipes were started at each pressure level of 4.5 and 2.5 bar. The average failure times are 2 754 h and 3 111 h, respectively.

## 6 Evaluation according to ASTM F 2023

According to the ASTM F 2023, the estimated time-to-failure shall be calculated at a hoop stress corresponding to a sustained internal pressure of 5.5 bar (80 psi) for the standard dimension ratio (SDR)<sup>9</sup> of the tested specimens, see Table 3, at the following temperature exposure conditions;

- I. 100% of the total time at 23°C (73°F)
- II. 100% of the total time at 60°C (140°F) aka CI-R
- III. 100% of the total time at 82°C (180°F)
- IV. 25% of the total time at 60°C (140°F) and 75% at 23°C (73°F) aka CI-TD

The conditions II and IV are often referred to as *Domestic continuous re-circulation (CI-R)* and *Traditional domestic (CI-TD)*, respectively.

For the conditions I-III the lifetime predictions will be done using multiple linear regression, for condition IV Miner's rule will also be applied.

### 6.1 Extrapolation hoop stress

The extrapolation hoop stress is based on the dimension ratio for the tested pipe. The following equation is used:

**Equation 3** Hoop stress equation

$$\sigma = P \cdot \left( \frac{SDR - 1}{2} \right)$$

Where:

$\sigma$	Extrapolation hoop stress
P	Internal pressure
SDR	Standard dimension ratio

Applying equation 3 to the tested material (SDR 9) at a pressure of 5.5 bar, gives an extrapolation hoop stress of 2.20 MPa.

**Table 4** Extrapolation hoop stress for the investigated material

Code	Nominal dimension	Standard dimension ratio (SDR)	Internal pressure	Extrapolation hoop stress
3527	16 x 1.8 mm	9	5.5 bar	<b>2.20 MPa</b>

<sup>9</sup> SDR is a selected series of numbers in which the average outside diameter to minimum wall thickness dimension ratios are constant for all sizes of tubing in each standard dimension ratio, and which are the ANSI Z17.1 Preferred Number Series R10 modified by +1.

2007-01-31

## 6.2 Multiple linear regression analysis

The regression analysis has been performed only using oxidative failure data, see Appendix B. Both the 3- and 4-parameter models have been applied, finally the 3-parameter model was chosen.

The analysis is based on all of the 12 data points, see Appendix B.

**Table 5** Result from the regression analysis performed according to ISO 9080 using the 3-parameter model.

Code	Correlation ( $R^2$ )	$C_1$	$C_2$	$C_3$	$C_4$
3527	0.980	-11.216	5 718.426	0	-189.425

According to ASTM F 2023 shall the correlation coefficient ( $R^2$ ) be  $>0.9$ . This requirement is fulfilled for the regression analysis of code 3527.

## 6.3 Lifetime calculations

The results from the calculations of the estimated time to failure for the different conditions stated in ASTM F 2023 are presented in Table 6 below.

**Table 6** Results from the lifetime calculations according to ASTM F 2023 for the pipe code 3527

Condition	Temperature	Hoop stress	Service time fraction	Estimated time to failure
I	23°C (73°F)	2.20 MPa	100%	>500 years
II (CI-R)	60°C (140°F)	2.20 MPa	100%	65 years
III	82°C (180°F)	2.20 MPa	100%	5.6 years
IV (CI-TD)	23°C (73°F)	2.20 MPa	75%	253 years
	60°C (140°F)	2.20 MPa	25%	

## 7 Additional comments

The delivered pipes showed no visual defects and no unusual behaviour were observed during the pressure testing of the PB pipe material PB4267 GREY.

2007-01-31

## **8        Referred documents**

ASTM F 2023 - 05

*Standard Test Method for Evaluating the Oxidative Resistance of Crosslinked Polyethylene (PEX) Tubing and Systems to Hot Chlorinated Water*

ISO 9080:2003

*Plastics piping and ducting systems - Determination of the long-term hydrostatic strength of thermoplastics materials in pipe form by extrapolation*

ISO 13760:1998

*Plastics pipes for the conveyance of fluids under pressure - Miner's rule - Calculation method for cumulative damage*

2007-01-31

**Client info**

---

Client: Basell Polyolefine GmbH  
Street adress: Industriepark Höchst, D 536  
Postal code: 65926 Frankfurt (M)  
Country: Germany  
Contact person: Dr. Klaus Könnecke  
Phone: +49(0)69-305 351 59  
Fax: +49(0)69-305 177 72  
Mail: klaus.koennecke@basell.com  
Web: www.basell.com

2007-01-31

**Material info**

---

Bodycote code:	3527
Trade name:	PB4267 Grey
Material:	PB
Colour:	Grey
Nominal dimension:	16 x 1.8 mm
Arrival date at Bodycote:	2005-01-26
Amount:	62 x 1.2 m
Cosignor:	Basell Polyolefine GmbH
Marking:	n/a
Resin producer (date, batch no.):	Basell Polyolefine GmbH (n/a)
Pipe producer (date, lot no.):	n/a

**Test info**

---

Test laboratory:	Bodycote Polymer			
Responsible:	Michael Falkhäll and Urban Westberg			
Test method:	ASTM F 2023-05			
Length (total/free):	350/300 mm			
Fittings:	PFA fittings			
Internal medium:	Chlorinated water			
External medium:	Air			
Conditioning time:	1 hour			
Flow rate:	54 dm <sup>3</sup> /h			
Chlorine source:	Sodium hypchlorite (NaOCl)			
Chlorine level:	Average	3.97 ppm	Standard deviation	0.08 ppm
pH:	Average	6.83	Standard deviation	0.08
ORP:	Average	878 mV	Standard deviation	15 mV

2007-01-31

**Table remarks**

---

Code	Internal Bodycote code
T	Test temperature
Date	Start date
$e_{min}$	Minimum wall thickness
$d_{em}$	Mean outside diameter
p	Internal pressure
$\sigma$	Circumferential stress (hoop stress)
->	The pipe is under test

**Pipe remarks**

---


No remarks

2007-01-31


**Testing with chlorinated water**

<b>Code</b>	<b>T</b> [°C]	<b>Date</b> [yymmdd]	<b>d<sub>em</sub></b> [mm]	<b>e<sub>min</sub></b> [mm]	<b>p</b> [bar]	<b>σ</b> [MPa]	<b>Failure time</b> [h]	<b>Failure mode</b>	<b>Test time</b>	<b>Remark</b>
<b>3527-3</b>	95	050218	16.12	1.83	6.0	2.34	12 587	Brittle		
<b>3527-4</b>	95	050218	16.12	1.83	6.0	2.34	14 112	Brittle		
<b>3527-1</b>	95	050218	16.12	1.82	4.5	1.77	16 099	Brittle		
<b>3527-2</b>	95	050218	16.14	1.83	4.5	1.76	15 745	Brittle		
<b>3527-7</b>	105	050221	16.12	1.84	4.5	1.75	4 901	Brittle		
<b>3527-8</b>	105	050221	16.12	1.84	4.5	1.75	5 682	Brittle		
<b>3527-5</b>	105	050221	16.12	1.83	3.0	1.17	8 039	Brittle		
<b>3527-6</b>	105	050221	16.11	1.83	3.0	1.17	8 327	Brittle		
<b>3527-11</b>	115	050221	16.13	1.84	4.5	1.75	2 671	Brittle		
<b>3527-12</b>	115	050221	16.11	1.85	4.5	1.73	2 837	Brittle		
<b>3527-9</b>	115	050221	16.12	1.84	2.5	0.97	3 120	Brittle		
<b>3527-10</b>	115	050221	16.12	1.84	2.5	0.97	3 101	Brittle		

2007-01-31



2007-01-31



**BODYCOTE/P-07/09**

**EVALUATION ACCORDING TO ASTM F 2023**  
Evaluation of the chlorine resistance according to ASTM F 2023 of the  
PB pipe material PB4267 GREY

**Mattias Svedberg**



Bodycote Polymer · SE-611 82 Nyköping · Sweden  
Phone +46 155 22 14 76 · Fax +46 155 26 31 25  
[www.bodycotepolymer.com](http://www.bodycotepolymer.com) · [info@bodycotepolymer.com](mailto:info@bodycotepolymer.com)